



Basic Plan Review

October 23, 2018
David F. Kokot, P.E.

DRAWN BY: DFK		
REVIEWED BY: DFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

183577
 REVDATE:102318
 KOKOT

D
 C
 B
 A

D
 C
 B
 A

8 7 6 5 4 3 2 1

Agenda

1. Background of plan review
2. Understanding basic terms
3. Tools Needed for Plan Review
4. Plan fundamentals
5. Reviewing plans
6. Reviewing a Building Plan
7. Reviewing a Site Plan
8. Reviewing Fire Sprinklers
9. Reviewing Fire Alarm
10. What to look out for
11. Practical Practice



DRAWN BY: DFK	 WASHINGTON STATE FIRE MARSHALS	DWG NO.	REV
REVIEWED BY: OFK			
SCALE: None			
DATE: 10/23/18			
TITLE:			

REVDATE:102318
 183577
 .KOKOT

D
 C
 B
 A

D
 C
 B
 A



8
 7
 6
 5
 4
 3
 2
 1

Background of Plan Review

Plan review is the process of evaluating plans developed by competent professionals that show how a building, site or system will be constructed in accordance with the applicable codes for the authority having jurisdiction.

Plans include drawings, calculations, specifications, material cut-sheets, manufacturer data, among others.

Plans can be paper or electronic.



DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

183577
REVDATE:102318
KOKOT

D
C
B
A

D
C
B
A

8

7

6

5

4

3

2

1

Background of Plan Review

The intent of plan review is to determine if the submitted design meets the minimum requirements of the codes in effect at the time of submission.

It does not mean that the reviewer has to correct or perform design on the plans for the design professional.

DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

REVDATE:102318
183577
KOKOT

D
C
B
A

D
C
B
A

8 7 6 5 4 3 2 1

Understanding basic terms

Authority Having Jurisdiction (AHJ) – The agency responsible for the compliance of the code.

Design Professional – person performing the design who is not a registered engineer or architect.

Licensed Professional – Licensed engineer or architect.

Registered Professional – Design or Licensed Professional that is allowed to perform design in a jurisdiction.

Plans – Product provided by registered professional showing the scope of work.

scope of Work – The extent of the work that is to be accomplished by the application for permit.

Application – The completion of the form to include drawings, specifications and equipment cut-sheets for the scope of work that is submitted to the AHJ for review and approval.

Approval – Status given to application that allows work to begin.

Revisions Required – Application not complete or does not meet the minimum requirements.


Conditional Approval – Status given to plans that require minor markups for approval. Markups (or redlines) can be provided by the AHJ.

“Almost Approved” – Close, but not close enough.

Construction Type – Type of Construction for the building


Occupancy Classification – Occupancy designation for all or part of a building.

Fire Area – The total area under the roof and extensions that are separated by fire barriers.

DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

183577
REVDATE:10/23/18
KOKOT

Understanding Basic Terms



* For complete information see International Building Code Table 601

A – protected combustible construction

B – non-protected combustible construction

Type IV is only Heavy Timber with no A or B
(so far)

DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

183577
REVDATE:102318
KOKOT

Understanding Basic Terms

Building Occupancy Type

A – Assembly

A1 – With fixed seating – theaters, TV studios, concert halls

A2 – Intended for food/drink – restaurants, bars, banquet halls

A3 – Worship, recreation, or amusement

A4 – Indoor sporting events

A5 – Outdoor activities

B – Business - Office, College classrooms, Banks, Labs, Ambulatory Care Facility

E – Education – Education of 6 or more through the 12 grade

F – Industrial

F1 – Moderate Hazard – combustible products

F2 – Low Hazard – non-combustible products

H – Hazardous

H1 – Detonation hazard

H2 – Deflagration hazard

H3 – Physical hazard

H4 – Health hazard

H5 – Semiconductor development

I – Institutional

I1, Group 1 >16 for 24 hour custodial care capable of evacuation

I1, Group 2 - >16 for 24 hour custodial

care need assistance for evacuation

I2 - >5 for 24 hour medical care

I3 - >5 for persons under restraint or security

M – Mercantile – stores, markets, sales

R – Residential

R1 – Transient

R2 – Non-Transient

R3 – Non-Transient not R1 or R2

S – Storage

S1 – Moderate-hazard storage – Furniture, clothing, hangar, etc.


S2 – Low-hazard storage – food, glass, metal products, parking garages

U – structures not classified in other occupancy – barns, carports, sheds, towers

183577
REVDATE:102318

DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

.KOKOT



Tools for Plan Review

Tools to Conduct an appropriate Plan Review:

1. Codes (paper or electronic) applicable to the review – IFC, NFPA, etc. – be sure to include current versions of State and local amendments!
2. Space large enough to comfortably review the plans with minimal interruption.
3. Means of measuring dimensions.
4. Technical resources.
5. Means of tracking progress and any comments.
6. Checklist of what needs to be provided.
7. Background or training in codes and construction.



DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

REVDATE:102318
183577
KOKOT

D
C
B
A

D
C
B
A

8 7 6 5 4 3 2 1



Tools for Plan Review

Code Resources:

I-Codes – Free read-only

<https://codes.iccsafe.org/public/collections/I-Codes>

State Amendments

<https://fortress.wa.gov/es/apps/sbcc/Page.aspx?nid=14>

DRAWN BY: DFK			
REVIEWED BY: OFK			
SCALE: None			
DATE: 10/23/18			
TITLE:	DWG NO.	REV	

183577
REVDATE:102318
KOKOT

D
C
B
A

D
C
B
A

8 7 6 5 4 3 2 1

Plan Fundamentals

Plans include:


1. Drawings of the work to be completed
2. Information about the designer
3. Signed and dated stamps (where necessary) of the design professional taking responsibility for the design
4. Scale of plans
5. North arrow
6. Title and drawing number
7. Specifications – companion bound text written to describe details and standards for the construction
8. Cut Sheets – manufacturer's information
9. Legend
10. Notes about specific items on the plan
11. Details
12. Construction type
13. Occupancy (single/mixed)

DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

REVDATE:102318
183577
KOKOT

Plan Fundamentals

Life Safety Plans



Occupant Load (for egress calculations) and
 Fire Load (for fire resistance calculations)

Egress Data

Number of Egress Routes: 1
 Egress Width: 100 ft
 Egress Length: 100 ft
 Egress Area: 10,000 sq ft

Building Fire Load Calculator

Fire Load Index: 1.0
 Fire Load Density: 1.0 lb/sq ft

Fire Resistance Requirements

Fire Resistance Rating: 1.0 hr
 Fire Resistance Type: 1.0 hr

General Notes

1. All fire resistance ratings are based on the fire resistance of the wall and ceiling assembly.

2. All fire resistance ratings are based on the fire resistance of the wall and ceiling assembly.

3. All fire resistance ratings are based on the fire resistance of the wall and ceiling assembly.



MOSS
 MOSS ENGINEERING & ARCHITECTURE
 1000 1st Avenue, Suite 1000
 Seattle, WA 98101
 Phone: (206) 461-1000
 Fax: (206) 461-1001
 Website: www.moss.com

Life Safety Plans
 A03

DRAWN BY: DFK		DWG NO.	REV
REVIEWED BY: OFK			
SCALE: None			
DATE: 10/23/18			
TITLE:			

REVDATE:102318 183577

D
C
B
A


D
C
B
A

8 7 6 5 4 3 2 1

Reviewing plans

To begin reviewing a set of plans:

1. Be sure that the set provided is complete.
2. Review the application for the scope and other information about the work (including address)
3. Review existing address for other permits or work that has been done.
4. Verify that the appropriate stamps have been provided on the plans.



DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

REVDATE:102318
 183577
 KOKOT

Reviewing a plan

The specific plan review conducted can vary depending upon the type of design, local requirements, and the type of system that is being provided.

1. Verify that the designer has indicated the correct code that is used.
2. Review the plans for clarity. Can the notes be read easily? Do references match notes?
3. Do the plans clearly indicate the work scope?
4. Are there variances or exceptions that are requested?

DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

1833577
REVDATE:102318
KOKOT

D
C
B
A

D
C
B
A

8 7 6 5 4 3 2 1

Reviewing a Plan

Now you can begin reviewing the plans:

1. Review each drawing to make sure that the work being done matches the information in the application.
2. Details need to be provided for any part of the plan that is not clear or can be confusing to understand what the intent is.
3. Review the application and all of the notes.

DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

183577
REVDATE:102318
KOKOT

D
C
B
A

D
C
B
A


8 7 6 5 4 3 2 1

Reviewing a Building Plan

1. Look over the plan for occupancy or fire separation (there is a difference).
2. Does the fire area trigger life safety systems?
3. Are there adequate egress paths?

Occupancy Separation

- Occupancies that have dissimilar risk factors are required to be separated by *fire barriers* or *horizontal assembly*
 - Required for horizontally adjacent spaces as well as vertically adjacent spaces
 - Note: when deciding on the rating for a *horizontal assembly* (floor/ceiling) make sure to check Building Type rating as well – use the strictest one.




DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

REVDATE:10/23/18 183577

KOKOT

Reviewing a Building Plan



General commercial building plan

DRAWN BY:	DFK
REVIEWED BY:	OFK
SCALE:	None
DATE:	10/23/18
TITLE:	



DWG NO.	
REV	

183577
REVDATE:102318
KOKOT

Reviewing a Site Plan


1. Review site for fire apparatus access.
 - A. Is there adequate width and clearances?
 - B. Does the access have adequate turning radius?
 - C. Is the surface of the drive acceptable?
 - D. Are there obstructions to the access?
 - E. Is aerial access required?
2. Review locations of fire hydrants, PIVs, FDCs.
 - A. Look for distances between hydrants and FDCs
 - B. Are these readily accessible?




DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

183577
REVDATE:102318
KOKOT


Reviewing a Site Plan




1. Make sure apparatus can get to within the required distance to buildings.
2. Verify street width and radii to allow for apparatus movement.
3. Dead-ends longer than 150' require compliant turn-around.
4. What about trees or other obstructions to buildings?




96' DIAMETER
CUL-DE-SAC




60-FOOT "Y"



MINIMUM CLEARANCE
AROUND A FIRE
HYDRANT



120' HAMMERHEAD



ACCEPTABLE ALTERNATIVE
TO 120' HAMMERHEAD

DRAWN BY: DFK

REVIEWED BY: OFK

SCALE: None

DATE: 10/23/18


TITLE:



DWG NO.

REV

Reviewing a Site Plan



The Berkshire Design Group, Inc.
 Landscape Architecture
 Planning
 Fire Reviewing
 1000
 (415) 482-7000

North Street Condominiums
 Changes of Parking Lot
 For Fire Truck Access

Date: 05/12/09
 Scale: 1"=20'
 Drawn By: MYL
 Sheet Number: SK-L1

DRAWN BY: DFK
 REVIEWED BY: OFK
 SCALE: None
 DATE: 10/23/18
 TITLE:



DWG NO. REV

What concerns would you have for site access, and For fire hydrant placement?

REVD: 10/23/18
 DATE: 05/12/09
 183577

8 7 6 5 4 3 2 1

D
 C
 B
 A

D
 C
 B
 A

Fire Sprinkler Review

Plans include:

1. Design density
2. Occupancy hazard classification
3. Type of fire sprinklers
4. Spacing of fire sprinklers
5. Bracing/seismic design
6. Pipe material
7. Wet or dry
8. Water supply
9. Remote areas
10. Hydraulic calculations

Fire Sprinkler Output Data										
Overall Pipe Output Data										
Seg. End.	Nodal K-Factor	Elevation (feet)	Discharge (gpm)	Residual Pressure (psi)	Nom. Dia. Inside Dia. C-Value	Q (gpm) Velocity (fps)	F. L./F T Fittings Type-Grp	Pipe Len. Fr Len. Tot Len.	PF-PSI PE-PSI PV-PSI	
10	5.65	20.00	15.50	7.52	2.50	3.82	0.00000	10.00	0.001	
20	5.65	20.00	15.50	7.52	2.47	0.26	0.00	0.000	
SCHED 40 WET STEEL										
40	5.65	20.00	15.05	7.09	1.50	14.96	0.00600	10.00	0.094	
30	5.65	20.00	14.96	7.00	1.61	2.36	0.00	0.000	
SCHED 40 WET STEEL										
50	0.00	20.00	0.00	7.54	2.50	11.67	0.00100	15.00	0.016	
20	5.65	20.00	15.50	7.52	2.47	0.78	E	6.00	0.000	
SCHED 40 WET STEEL										
50	0.00	20.00	0.00	7.54	1.50	29.97	0.03400	5.00	0.444	
40	5.65	20.00	15.05	7.09	1.61	4.72	T	8.00	0.000	
SCHED 40 WET STEEL										
60	0.00	20.00	0.00	7.58	2.50	11.67	0.00100	25.00	0.058	
10	5.65	20.00	15.50	7.52	2.47	0.26	E	6.00	0.000	
SCHED 40 WET STEEL										
60	0.00	20.00	0.00	7.58	1.50	30.05	0.03400	5.00	0.001	
70	0.00	20.00	0.00	7.58	1.50	30.05	0.03400	5.00	0.001	

Sample Reports


Fire Sprinkler Output Summary	
Hydraulically Most Demanding Sprinkler Node	
HMD Sprinkler Node Number:	30
HMD Actual Residual Pressure:	7.00 psi
HMD Actual QPM:	14.96 gpm
Sprinkler Summary	
Sprinkler System Type:	Wet
Specified Area Of Application:	600.00 ft²
Minimum Desired Density:	0.00 gpm/ft²
Actual Density:	0.15 gpm/ft²
Actual Area Per Sprinkler:	100.00 ft²
Sprinkler Flow:	91.08 gpm
Average Sprinkler Flow:	15.18 gpm
Flow Velocity And Imbalance Summary	
Maximum Flow Velocity (In Pipe 90 - 100)	9.45 fps
Maximum Velocity Pressure (In Pipe 60 - 70)	0.01 psi
Allowable Maximum Nodal Pressure Imbalance:	0.010 psi
Actual Maximum Nodal Pressure Imbalance:	0.007 psi
Actual Average Nodal Pressure Imbalance:	0.001 psi
Actual Maximum Nodal Flow Imbalance:	0.037 gpm
Actual Average Nodal Flow Imbalance:	0.017 gpm
Overall Network Summary	
Number Of Unique Pipe Sections:	10
Number Of Flowing Sprinklers:	6
Sprinkler Flow:	91.08 gpm
Non-Sprinkler Flow:	53.00 gpm
Total System Demand Flow:	141.08 gpm
Minimum Required Residual Pressure At System Inflow Node:	20.44 psi
Demand Flow At System Inflow Node:	140.97 gpm



DRAWN BY: DFK		
REVIEWED BY: DFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

Fire Sprinkler Review


1. Occupancy Hazard Classification (NFPA 13)
 1. Light Hazard
 2. Ordinary Hazard Group 1
 3. Ordinary Hazard Group 2
 4. Extra Hazard Group 1
 5. Extra Hazard Group 2



DRAWN BY: DFK		
REVIEWED BY: DFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

183577
 REV DATE: 10/23/18
 DFK/DFK

Reviewing a Sprinkler Plan



Remote Area – Area with the most impact to the operation of a sprinkler system in a fire condition.

DRAWN BY: DFK

REVIEWED BY: OFK

SCALE: None

DATE: 10/23/18

TITLE:





DWG NO.

REV

Fire Alarm Review

1. Type of system
2. Central monitoring and type
3. Voice or emergency evacuation
4. Secondary power
5. System voltage loss
6. Placement of devices – does it meet listing?
7. Environment being protected



ITEM	DESCRIPTION	STANDBY CURRENT PER UNIT (AMPS)	QTY	STANDBY CURRENT PER UNIT (AMPS)	ALARM CURRENT PER UNIT (AMPS)	QTY	SYSTEM ALARM CURRENT (AMPS)
1	FACP	0.0200	1	0.1750	1.0000	1	1.0200
2	Smoke Det	0.0000	2	0.0000	0.0000	2	0.0000
3	Call Pt	0.0000	2	0.0000	0.0000	2	0.0000
4	Hand/Horn	0.0000	2	0.0000	0.0000	2	0.0000
5	Smoke Relay	0.0000	2	0.0000	0.0000	2	0.0000
TOTAL (SYSTEM STANDBY CURRENT (AMPS))					0.1750		3.02

REQUIRED OPERATING TIME OF SECONDARY POWER (SOURCE FROM NFPA 72 10.6.2.1)
 STANDBY: 24 HOURS ALARM: 5 MINUTES + 14 COURSE HOURS

REQUIRED STANDBY TIME (HOURS)	TOTAL SYSTEM STANDBY CURRENT (AMPS)	REQUIRED STANDBY CAPACITY (AMP-HOURS)	REQUIRED ALARM TIME (HOURS)	TOTAL SYSTEM ALARM CURRENT (AMPS)	REQUIRED ALARM CAPACITY (AMP-HOURS)
24	0.1750	4.2000	5	3.02	1.5100


REQUIRED STANDBY CAPACITY (AMP-HOURS)	REQUIRED ALARM CAPACITY (AMP-HOURS)	TOTAL REQUIRED CAPACITY (AMP-HOURS)	NO FOR OF BATTERY	REQUIRED BATTERY CAPACITY (AMP-HOURS)
4.2000	1.5100	5.7100	1.2	8.85

Sample Battery Calculation.

DRAWN BY: DFK	
REVIEWED BY: OFK	
SCALE: None	
DATE: 10/23/18	TITLE:
DWG NO.	REV

REVDATE:102318 183577

Reviewing a Fire Alarm Plan



DRAWN BY: DFK
 REVIEWED BY: OFK
 SCALE: None
 DATE: 10/23/18



TITLE:	DWG NO.	REV

REVDATE:102318 183577

A B C D

A B C D

8 7 6 5 4 3 2 1

Reviewing a Plan

What happens if you run into a situation that you have not encountered before?

- Review code and commentary
- Review errata
- Contact plan reviewer in an adjacent jurisdiction
- Contact a plan reviewer from another jurisdiction

DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

183577
REVDATE:102318
KOKOT

D
C
B
A


D
C
B
A

8 7 6 5 4 3 2 1

What to look out for

There are several items to look out for to be sure that the plans are complete.


1. Do the plans provide a 3-dimensional understanding of the work?
 - A. i.e.: The plans are of a small warehouse. How tall is the building? Why is that important?
2. Does the declared occupancy match the proposal?
 - A. i.e.: Community center (A3 occupancy) will be used for banquets
3. The occupant load in the code summary states 87 occupants, and the plans show 105 seats.
4. Rooms not labeled for use.

DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

REVDATE:102318
183577
KOKOT

8 7 6 5 4 3 2 1

What to look out for



FIRST (GROUND) FLOOR PLAN

AS OF JUNE, 1997 NORTH →

SCALE: 0 16 32 48 64 FEET

Does this floor plan give enough information to do a building or site review?

DRAWN BY: DFK

REVIEWED BY: OFK

SCALE: None

DATE: 10/23/18

TITLE:



DWG NO.

REV

183577
REVDATE:102318

.KOKOT

What to look out for

2. Do the plans provide a scale that they were drawn to?
Does the scale match the plan?

i.e.: The title block states that the plan is $1/8" = 1'-0"$,
but a measurement indicates that it is drawn to $1/4" = 1'-0"$.

DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

1833577
REVDATE:102318
KOKOT

D
C
B
A


D
C
B
A

8 7 6 5 4 3 2 1

What to look out for

3. Can the plans be clearly read?

i.e.: The plans may have multiple lines that obstruct note callouts or other text that cannot be read






DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

REVDATE:102318 183577
KOKOT

D
C
B
A

D
C
B
A

8 7 6 5 4 3 2 1



General Notes

- 1 - THIS INSTALLATION SHALL SATISFY THE MINIMUM REQUIREMENTS OF NFPA 13A, IBC AND IFC.
- 2 - ALL PIPING SHALL BE SUPPORTED AND BRACED IN ACCORDANCE WITH NFPA 13A. GENERALLY, ALL NEW PIPING SHALL BE RIGID W/ 1/2\"/>

Sprinkler Symbol Notes:

- ⊙ Upright on 1" Spring Up
- ⊙ Upright on 1 x 1/2 x 1 Tee w/ Plug
- ⊙ Upright on 1 x 1/2 x 1 Tee w/ Drop to Pendant

HYDRATIC REMOTE AREA #3
 DENSITY = 0.10/93 + 100 GPM HOSE (LIGHT HAZARD)
 REQUIREMENT AT BASE OF RISER = 246.54 GPM AT 71.028 PSI (CET - CONNECTION TO #4 UNDERGROUND SUPPLY)

REF: NFPA #13 (2007) 11.2.3.2.3
 $Y_1 = \frac{3}{2} \times 155 = 232.5$ HIGHEST CEILING ENCOUNTERED IN DESIGN AREA = 11'-0" AFF
 $Y_2 = \frac{3}{2} \times 155 = 232.5$ 455 = 37.308
 Y= REDUCTION ALLOWED FROM 1500 SF REMOTE AREA (MINIMUM REDUCTION = 45%)
 MINIMUM REMOTE AREA = 630 SF (MINIMUM TYP. SPRINKLERS)

HYDRATIC REMOTE AREA #4
 DENSITY = 0.10/93 + 100 GPM HOSE (LIGHT HAZARD)
 REQUIREMENT AT BASE OF RISER = 338.428 GPM AT 71.028 PSI (CET - CONNECTION TO #4 UNDERGROUND SUPPLY)

REF: NFPA #13 (2007) 11.2.3.2.3
 $Y_1 = \frac{3}{2} \times 155 = 232.5$ HIGHEST CEILING ENCOUNTERED IN DESIGN AREA = 11'-0" AFF
 $Y_2 = \frac{3}{2} \times 155 = 232.5$ 455 = 38.508
 Y= REDUCTION ALLOWED FROM 1500 SF REMOTE AREA (MINIMUM REDUCTION = 45%)
 MINIMUM REMOTE AREA = 822.5 SF (MINIMUM TYP. SPRINKLERS)

HYDRATIC REMOTE AREA #5
 DENSITY = 0.10/93 + 100 GPM HOSE (LIGHT HAZARD)
 REQUIREMENT AT BASE OF RISER = 245.33 GPM AT 82.222 PSI (CET - CONNECTION TO #4 UNDERGROUND SUPPLY)

REF: NFPA #13 (2007) 11.2.3.2.3
 $Y_1 = \frac{3}{2} \times 155 = 232.5$ HIGHEST CEILING ENCOUNTERED IN DESIGN AREA = 7'-0" AFF
 $Y_2 = \frac{3}{2} \times 155 = 232.5$ 455 = 41.508
 Y= REDUCTION ALLOWED FROM 1500 SF REMOTE AREA (MINIMUM REDUCTION = 45%)

SHEET KEYNOTES

1. 8" D.I. Underground Fire Line w/ Yard PIV (By Others).
2. 8" Lead In w/ 4" Galv. Main Down To 4" Areas Max M300BFG Double Check Detector Assembly.
3. 4" Riser w/ 8-Ry Va. & Dry Pipe Valve To Feed Dry Alarm System And 2" Riser w/ 8-Ry Va. To Feed Wet System.
- 3.1. Interconnected Main Drain And Aux. Drains. Route 2" Main Drain Up And Out. Route 1" Aux. Drain To Floor Drain.
4. 4" FDC Main Up To First Floor. Field Route And Coordinate w/ Other Trades. 4" Main, Check Valves And Ball Dry Not Shown For Clarity.
5. 4" (Dry) And 2" (Wet) Mains Up To Feed Floors Above.
6. Rufft Areas Filled w/ HVAC Duct Work. No Sprinkler Coverage. Future HVAC Duct Work (Dashed).
7. Slope Line Down w/ Slope.
8. 4" Grooved Tee w/ 45° Grooved Reducing Coupling. 4" Dry Main Continues Up To Feed First Floor Also Area. Route 2" Dry Main To Feed Loft Also Area.
10. 90° 2" Fittings Grooved 90°s Up Face To Face.
11. (1) 2" Wet And (1) 2" Dry Main Up To Feed Loft Area.
12. Gang Drain Discharge For Wet And Dry Insp. Tee(s) Located In Loft Area. Inset 2" Offset Outlet.
13. Exposed Sprinkler Piping In Unfinished Loft Area.
14. Wet And Dry Insp. Test Valve Location. Tie Together For Gang Drain To First Floor And Discharge To Exterior.

REVISIONS		SPRINKLER SYMBOL DESCRIPTION								
D	REV. DATE	SYMBOL	TYPE	MODEL	MARK	FRISK	STRE	TEMP	K-FACTOR	TEMP
1	RELEASE (September 3, 2010)	⊙	TY	TY-FIB	TYCO	BRASS	COMB	150° F	5.60	25
2		⊙	TY	TY-FIB	TYCO	BRASS	COMB	150° F	5.60	5.3
3		⊙	TY	TY-FIB	TYCO	BRASS	COMB	200° F	5.60	3
4		⊙	TY	TY-FIB	TYCO	BRASS	COMB	150° F	5.60	5
5		⊙	TY	TY-FIB	TYCO	WHITE	COMB	150° F	5.60	5
6		⊙	TY	TY-FIB	TYCO	WHITE	COMB	150° F	5.60	112
7		⊙	TY	TY-L	TYCO	WHITE	COMB	212° F	5.60	6
		TOTAL SPRINKLERS SHOWN ON THIS SHEET: 228								
		TOTAL SPRINKLERS REQUIRED IN THE DESIGN: 300								

PROJECT
 Grand Center Medical Office
 3700 E. Grand Blvd.
 Spokane, WA 99203

FIRE PROTECTION

DRAWN BY: DFK
 REVIEWED BY: OFK
 SCALE: None
 DATE: 10/23/18



TITLE: _____ DWG NO. _____ REV _____

This plan would not easy to read – even if you could read it!

REVDATE:102318
 183577
 KOKOT

Plan Review Questions


1. I am remodeling an existing building. Will I need to install fire sprinklers?
2. If I have 85 seats but only allow 49 customers at a time, do I still need to provide a second egress?
3. I am putting a daycare in the basement of a church. Is there anything that I need to be aware of?
4. Well, the space was used as an apartment, so doesn't that grandfather it?
5. Can I open my business and install fire sprinklers once I have the income?
6. "Seattle does not do this, why do have to do that here?"
7. How come you guys always look at the negative?

DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

D.KOKOT
REVDATE:10/23/18
183577

Practical Practice

Let's review a few plans and see what we can find.




DRAWN BY: DFK
 REVIEWED BY: OFK
 SCALE: None
 DATE: 10/23/18
 TITLE:



DWG NO. REV

183577
REVDATE:102318
KOKOT

8 7 6 5 4 3 2 1



Residential Site Plan

What would you need to look at for a single family residence?


DRAWN BY: DFK
 REVIEWED BY: OFK
 SCALE: None
 DATE: 10/23/18



TITLE:	DWG NO.	REV

REVDATE:10/23/18 1835:77

KOKOT



TOTAL LOT AREA = 22,186 S.F.
 TOTAL BUILDING AREA = 2,952 S.F.
 LOT COVERAGE = 12.71% S.F.
 TOTAL IMPERVIOUS = 15,668 S.F.
 PARKING STALLS = 29

SETBACKS
 PARKING SETBACK = 5 FEET
 REAR SETBACK = 20 FEET
 SIDE SETBACK = 10 FEET
 FRONT SETBACK = 10 FEET MINIMUM, 20 FEET MAXIMUM

PROPERTY DESCRIPTION
 Parcel 1:
 Lots 4 and 5, Block 1, Martin's Addition to Anoka, except that part of Lot 5 taken for highway purposes, according to the recorded plat thereof, Anoka County, Minnesota.
 Parcel 2:
 That part of Lot 6, Block 1, Martin's Addition to Anoka, according to the recorded plat thereof, Anoka County, Minnesota, lying Northerly of the Northerly right of way of Minnesota State Trunk Highway Number 10, as laid out and traveled September 4, 1968.

EXISTING ZONING
 R-1

Feb 10, 2017 - 10:43am
 C:\Users\jerry\Documents\PROJECTS\2017\20170210\20170210.dwg

DATE	REVISION



MINNESOTA FIREARMS

SITE PLAN
 CITY OF ANOKA, MINNESOTA
 SHEET 2 OF 5 SHEETS
 4121.01


What concerns would you have with this commercial building?

DRAWN BY: DFK
 REVIEWED BY: DFK
 SCALE: None
 DATE: 10/23/18
 TITLE:




DWG NO.	REV

REVDATE:102318
 183577
 .KOKOT



FOR FULL LEGEND
SEE SHEET C0.0

- PCC CONCRETE
- BICYCLE RACK LOCATION
- FIRE TRUCK TURNING RADIUS 25' INSIDE TURNING RADIUS WITH 50' OUTSIDE TURNING RADIUS.



NAVD - 88
FOR SURVEY & ASSOCIATE BASIS OF BEARING, PER
RECORD OF SURVEY NO. 417947, RECORDED IN VOLUME
79 OF SURVEYS, AT (PAGES) 89-92, IN SPOKANE COUNTY
WASHINGTON.

NO.	DATE	DESCRIPTION
1	10/23/18	CONSTRUCTION SET
2	10/23/18	SEWER COMMENTS #1
3	10/23/18	AGENCY COMMENTS #3
4	10/23/18	AGENCY COMMENTS #2
5	10/23/18	AGENCY COMMENTS #1
6	10/23/18	AGENCY COMMENTS
7	10/23/18	PERMIT SET

SCALE:	PROJECT #:	10-1560
HORIZONTAL:	DATE:	10/31/18
VERTICAL:	DRAWN:	TEW
	REVIEWED:	TEW

**COPPER RIVER APARTMENTS
FIRE TRUCK RADIUS
2911 W. FORT GEORGE WRIGHT DRIVE
SPOKANE, WASHINGTON**

**SHEET
C3.11
JOB NUMBER
15-1560**

What concerns would you have with this commercial building?


DRAWN BY: DFK
REVIEWED BY: OFK
SCALE: None
DATE: 10/23/18
TITLE:



DWG NO. REV

183577
REVDATE:102318
KOKOT

8 7 6 5 4 3 2 1




What concerns would you have with this fire sprinkler design?

DRAWN BY: DFK		<p>WASHINGTON STATE FIRE MARSHALS</p>
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:		DWG NO.
		REV

183577
REVDATE:102318
KOKOT

REVDATE:10/23/18
KOKOT



FIRE ALARM POWER SUPPLY VOLTAGE DROP WORKSHEET FOR NOTIFICATION APPLIANCE CIRCUITS

Device	Rating	Distance	Current	Drop	Notes
Device 1	100VA	100'	0.5A	0.1V	
Device 2	100VA	100'	0.5A	0.1V	
Device 3	100VA	100'	0.5A	0.1V	
Device 4	100VA	100'	0.5A	0.1V	
Device 5	100VA	100'	0.5A	0.1V	

BATTERY CALCULATIONS FOR 24VDC AUXILIARY POWER SUPPLY

Device	Rating	Distance	Current	Drop	Notes
Device 1	100VA	100'	0.5A	0.1V	
Device 2	100VA	100'	0.5A	0.1V	
Device 3	100VA	100'	0.5A	0.1V	
Device 4	100VA	100'	0.5A	0.1V	
Device 5	100VA	100'	0.5A	0.1V	

- NOTES:**
- NEW SILC DEVICES TO BE ADDRESSED IN THE FIELD AND TIED INTO NEAREST EXISTING CIRCUIT.
 - ALL DEVICES OUTSIDE OF AREA OF WORK ARE EXISTING.

FIRE ALARM CABLE/LINETYPE LEGEND

CABLE LINETYPE	NFPA 72 CIRCUIT TYPE	TYPICAL DEVICES	CONDUCTORS
A	SIGNALING LINE CIRCUIT	SMOKE/HEAT	18/2 PPLR
B	NAC (NOTIFICATION APPLIANCE CIRCUIT)	AUDIBLE/VISUAL DEVICES (HORNS/STROBES)	14/2 PPLR

APPLICABLE CODES

AUTHORITY HAVING JURISDICTION: CITY OF SPOKANE
 BUILDING CODE: INTERNATIONAL BUILDING CODE, 2015 EDITION
 FIRE CODE: INTERNATIONAL FIRE CODE, 2015 EDITION/SWC
 NFPA 72 COMPANY: NFPA 72
 STANDARDS: NFPA 70, NATIONAL ELECTRIC CODE - ARTICLE 760
 NFPA 72, 2013

FIRE ALARM LEGEND

SYMBOL	EQUIPMENT	MANUFACTURER	PART NUMBER	BACKBOX	RING	MT. HEIGHT	QTY.
INSP	FIRE ALARM CONTROL PANEL (EXISTING)	SILENT KNIGHT	SK5820	--	--	--	--
F	PULL STATION (EXISTING)	SILENT KNIGHT	SK-PULL-DA	--	--	--	--
APS	AUXILIARY POWER SUPPLY (EXISTING)	SIEMENS	PAD-3	EN-PAD	N/A	AS REQUIRED	--
Ⓜ	HEAT DETECTOR (EXISTING)	SILENT KNIGHT	SK-HEAT	4/SQ.	1-GANG	CEILING	--
Ⓢ	SMOKE DETECTOR	SILENT KNIGHT	SK-PHOTO	4/SQ.	1-GANG	CEILING	1
Ⓜ	STROBE (CEILING)	SIEMENS	ZR-MC-CW	4/SQ.	1-GANG	CEILING	2
Ⓜ	HORN/STROBE (CEILING)	SIEMENS	ZH-MC-CW	4/SQ.	1-GANG	CEILING	1
F	END-OF-LINE DEVICE	--	--	--	--	--	--



HUTTON/STCU BLDG.
 4 TH FLOOR CORRIDOR
 5 WASHINGTON
 SPOKANE, WA 99201

REVISION

NO.	DATE	DESCRIPTION
1		ISSUE FOR PERMIT

FORM NO. 4854
 Checked by: MDP
 Designed by: AAR
 Date: 08/27/2018
 Scale: 1/18" = 1'
 SHEET TITLE: FIRE ALARM PLAN

SHEET NO. FA1.0

What concerns would you have with this fire alarm design?

DRAWN BY: DFK
 REVIEWED BY: OFK
 SCALE: None
 DATE: 10/23/18
 TITLE:



DWG NO.	REV
---------	-----

D

D

Final Thoughts

C

C

Consistency is critical to successful plan review

As easy as this sounds, it can be challenging as no two projects are exactly the same and the Code is not specific enough for all buildings.



B

B

No matter your opinion, the Code needs to be followed

To step away from the basic code requirements is what a slippery slope refers to.

A

A

DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

REVDATE:102318
 183577
 .KOKOT

8 7 6 5 4 3 2 1

D

D

C

C

B

B

A

A

Questions?

REVDATE:102318 183577
KOKOT

8 7 6 5 4 3 2 1

DRAWN BY: DFK		
REVIEWED BY: OFK		
SCALE: None		
DATE: 10/23/18		
TITLE:	DWG NO.	REV

REVISIONS				
ZONE	REV	DESCRIPTION	DATE	APPROVED

Contact Information

David F. Kokot, P.E.
 Fire Protection Engineer
 Spokane Fire Department

(509) 625-7056
 dkokot@spokanefire.org

DRAWN BY: DFK
REVIEWED BY: DFK
SCALE: None
DATE: 10/23/18
TITLE:



DWG NO.	REV
---------	-----

REVDATE:102318 183577